

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7272-0085:198 Page 1 of 1

**CATEGORY:** Photoelectric Smoke Detector

**LISTEE:** ADT Security Services, 5400 West Rosecrans Avenue, Hawthorne, CA 90250-6609  
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942\*

**DESIGN:** Models 2351ADT and 2351TADT photoelectric type smoke detectors. Model 2351TADT employs a supplemental heat sensor to assist the smoke detector. This heat sensor is not intended for use as a heat detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, product number, electrical rating and UL label.

**APPROVAL:** Listed as photoelectric type smoke detector for use with listee's separately listed compatible base and fire alarm control units. Models 2351ADT and 2351TADT are suitable for open areas and inside duct installation with air velocities between 0-4000 fpm.

**XLF:** 7272-0028:206

\*rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager